

Header test

Device Calibration Check: Rev 1.0

File: C:\Users\jdobos\HART CalChecks\T-11402A_20211022_151033

Tag: T-11402A

LongTag/Msg: PUMP 2

Model: PR 5335

Device ID: 1041396

Date (yyyy-mm-dd): 2021-10-22

Time (hr:mn:sc): 03:11:39 PM

Tech: J. Dobos

Notes: Test the string2

URV: 1200.0 degC

LRV: -180.0 degC

Number of Points: 3

Calibration Type: As Found

Calibrator: Tegam 948A, SN: 522695-0002, Cal Due: 2022/12/23

Point	PV Expected	PV Read	PV Error	AO Expected	AO Read	AO Error
1	-180.00 degC	-179.88 degC	0.01 %	4.00 mA	4.02 mA	0.13 %
2	510.00 degC	509.99 degC	0.00 %	12.00 mA	11.94 mA	0.38 %
3	1200.00 degC	1199.78 degC	0.02 %	20.00 mA	20.00 mA	0.00 %

I certify that this electronic signature is the legal equivalent to my hand written signature.
I further certify that I performed the Calibration Check on the indicated date and that I followed the appropriate procedures.

Signed by: J. Dobos 2021-10-22