

header test 2

Device Calibration Check: Rev 1.0

File: C:\Users\jdobos\FF CalChecks\FT106-1_20220523_152931

Tag: FT106-1

Model: EJA (Software Download)

Device ID: 5945430008J0016034

DD: \594543\0008\0105.ffa

Date (yyyy-mm-dd): 2022-05-23

Time (hr:mn:sc): 03:29:41 PM

Tech: test 2

Notes: notes test 2

PV: Analog Input (4000): Field Value.Value

URV: 400 %

LRV: 200 %

Number of Points: 3

Calibrator: Tegam 948A, SN: 123456, Cal Due: 2024/02/28

Calibration Type: As Found

Point	PV Expected	PV Read	PV Error
1	200.000000 %	0.0035532 %	100.00 %
2	300.000000 %	0.0035532 %	150.00 %
3	400.000000 %	-0.019105 %	200.01 %

I certify that this electronic signature is the legal equivalent to my hand written signature.
I further certify that I performed the Calibration Check on the indicated date and that I followed the appropriate procedures.

Signed by: gfgfgfg 2022-05-23